




DELHI JAL BOARD ;(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT HAIDERPUR,
DELHI-110085



(ISO Certified 9001:2015)

**THE TEST REPORT IS
FOR THIS PARTICULAR
WATER SAMPLE ONLY**

Water samples collected from:- S1:- Outlet of Storage tank (DJB Supply) S2:- Drinking Point after R.O. in the premises of MRG SCHOOL, Sector -3, Rohini, New Delhi-85, vide challan no. 173, dated 24.08.2026.

S. No.	PARAMETERS	UNITS	B.I.S.10500:2012		S1	S2
			Desirable	Permissible		
1.	Date of Collection	--	----	----	-----27.08.2026-----	
2.	Date of Analysis	--	----	----	-----27.08.2026-----	
3.	Colour	C.U.	5	15	<1.0	<1.0
4.	Odour	--	Agreeable		Agreeable	Agreeable
5.	Turbidity	N.T.U.	1.0	5.0	3.61	0.21
6.	pH value	--	6.5 to 8.5	N.R.	7.35	6.78
7.	Electrical Conductivity	µmhos/cm	-----	-----	235.0	106.0
8.	Total Dissolved Solid	(mg/l)	500	2000	153.0	69.0
*	CHEMICAL EXAMINATION					
9.	Phenolphthalein Alkalinity	(mg/l)	-----	----	Nil	Nil
10.	Total Alkalinity	(mg/l)	200	600	71.0	31.0
11.	Total Hardness	(mg/l)	200	600	102.0	28.0
12.	Calcium Hardness	(mg/l)	-----	-----	69.0	10.0
13.	Magnesium Hardness	(mg/l)	---	-----	33.0	18.0
14.	Calcium as Ca	(mg/l)	75	200	27.0	04.0
15.	Magnesium as mg	(mg/l)	30	100	7.9	4.3
16.	Ammonia (as NH ₃ -N)	(mg/l)	0.5	N.R.	ND	ND
17.	Nitrite –Nitrogen (N)	(mg/l)	---	---	ND	ND
18.	Nitrate NO ₃	(mg/l)	45	N.R.	3.50	3.81
19.	Sulphate (SO ₄)	(mg/l)	200	400	34.89	29.39
20.	Chloride (Cl)	(mg/l)	250	1000	13.0	9.00
21.	Iron (Fe)	(mg/l)	1.0	N.R.	0.24	0.02
22.	Fluorides (F)	(mg/l)	1.0	1.5	0.54	0.50
23.	Cyanides (CN)	(mg/l)	0.05	N.R.	ND	ND
24.	Residual Chlorine	(mg/l)	0.2	1.0	1.0	Ni
*	BACTERIOLOGICAL EXAMINATION					
25.	Coli form per 100 ml at 37 ⁰ c	MPN/100 mL	00		0	0

Remarks:- On the basis of tested parameters, water samples 'S1' and 'S2' confirms to drinking water specification IS.10500:2012 and may be used for drinking purpose.

Asstt. Chemist

Chemist/Bacteriologist

Assistant Water Analyst
A.C.W.A. (HP-II)
Delhi Jal Board, Delhi-85
Govt. of N.C.T. of Delhi

SRISHTI Digitally signed
GOEL by SRISHTI GOEL
Date: 2026.09.28
14:52:38 +05'30"

Municipal Corporation of Delhi
(Office of Dy. Health Officer: Rohini Zone)
Public Health Department
Sec-5, Rohini, Delhi-85

NO.DHO/RZ/2025/...846.....

Dated: 5/12/25

SCHOOL HEALTH CERTIFICATE

It is certified that an inspection team headed by area Public Health Inspector from Public Health department Rohini Zone inspected the **MRG SCHOOL** at **PKT-B-5, SEC-3, ROHINI-110085** and found that the MRG SCHOOL has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitary condition in the school building & the campus.

The above certificate is valid for the period of **one year** from date of issue.


Dy. Health Officer
Rohini Zone


PRINCIPAL
MRG SCHOOL PKT-B-5, SEC-3
ROHINI-110085



**SRISHTI
GOEL** Digitally signed
by SRISHTI GOEL
Date: 2026.09.28
14:14:32 +05'30'



DELHI JAL BOARD ; (GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT HAIDERPUR,
DELHI-110085



(ISO Certified 9001:2015)

**THE TEST REPORT IS
FOR THIS PARTICULAR
WATER SAMPLE ONLY**

Water samples collected from:- S1:- Outlet of Storage tank (DJB Supply) S2:- Drinking Point after R.O. in the premises of MRG SCHOOL, Sector -3, Rohini, New Delhi-85, vide challan no. 173, dated 24.08.2026.

S. No.	PARAMETERS	UNITS	B.I.S.10500:2012		S1	S2
			Desirable	Permissible		
1.	Date of Collection	--	----	----	-----27.08.2026-----	
2.	Date of Analysis	--	----	----	-----27.08.2026-----	
3.	Colour	C.U.	5	15	<1.0	<1.0
4.	Odour	--	Agreeable		Agreeable	Agreeable
5.	Turbidity	N.T.U.	1.0	5.0	3.61	0.21
6.	pH value	--	6.5 to 8.5	N.R.	7.35	6.78
7.	Electrical Conductivity	µmhos/cm	-----	-----	235.0	106.0
8.	Total Dissolved Solid	(mg/l)	500	2000	153.0	69.0
* CHEMICAL EXAMINATION						
9.	Phenolphthalein Alkalinity	(mg/l)	-----	-----	Nil	Nil
10.	Total Alkalinity	(mg/l)	200	600	71.0	31.0
11.	Total Hardness	(mg/l)	200	600	102.0	28.0
12.	Calcium Hardness	(mg/l)	-----	-----	69.0	10.0
13.	Magnesium Hardness	(mg/l)	---	----	33.0	18.0
14.	Calcium as Ca	(mg/l)	75	200	27.0	04.0
15.	Magnesium as mg	(mg/l)	30	100	7.9	4.3
16.	Ammonia (as NH ₃ -N)	(mg/l)	0.5	N.R.	ND	ND
17.	Nitrite -Nitrogen (N)	(mg/l)	---	---	ND	ND
18.	Nitrate NO ₃	(mg/l)	45	N.R.	3.50	3.81
19.	Sulphate (SO ₄)	(mg/l)	200	400	34.89	29.39
20.	Chloride (Cl)	(mg/l)	250	1000	13.0	9.00
21.	Iron (Fe)	(mg/l)	1.0	N.R.	0.24	0.02
22.	Fluorides (F)	(mg/l)	1.0	1.5	0.54	0.50
23.	Cyanides (CN)	(mg/l)	0.05	N.R.	ND	ND
24.	Residual Chlorine	(mg/l)	0.2	1.0	1.0	Nil
* BACTERIOLOGICAL EXAMINATION						
25.	Coli form per 100 ml at 37°C	MPN/100 mL	00		0	0

Remarks:- On the basis of tested parameters, water samples 'S1' and 'S2' confirms to drinking water specification IS.10500:2012 and may be used for drinking purpose.

Asstt. Chemist

Chemist/Bacteriologist

Assistant Water Analyst
A.C.W.A. (HP-II)
Delhi Jal Board, Delhi-85
Govt. of N.C.T. of Delhi

