



NORTH DELHI MUNICIPAL CORPORATION
OFFICE OF DEPUTY HEALTH OFFICER
PUBLIC HEALTH DEPARTMENT: ROHINI ZONE
SECTOR-5, ROHINI, DELHI

NO: DHO/RZ/2021/210

Date: 16/07/2021

SCHOOL HEALTH CERTIFICATE

It is certified that an inspection team headed by Public health Inspector from Public Health department Rohini Zone inspected the MRG SCHOOL SITUATED AT PKT. B-5, SECTOR-3, ROHINI, DELHI-110085 and found that MRG SCHOOL has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic and sanitation condition in the school building & the campus.

The above certificate is valid till 31.03.2022.



PRINCIPAL
MRG SCHOOL
PKT. B-5, SECTOR-3,
ROHINI, DELHI-110085

Dy. Health Office
Rohini Zone

Deputy Health Officer
North Delhi Municipal Corporation
Rohini Zone



DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT HAIDERPUR, DELHI-110085.
THE TEST REPORT IS
FOR THE PARTICULAR
WATER SAMPLE ONLY



Water sample collected from DJB supply in the premises of 'MRG School', sector-103, Rohini, New Delhi-110085, vide Chellan no. 208 dated 18.03.2021.

S. No.	PARAMETERS	UNITS	Limit as per B.I.S.10500:2012		S1
			Acceptable	Permissible	
1.	Date of collection	--	---	---	24.03.2021
2.	Date of Analysis	--	---	---	26.03.2021
3.	Colour	Hazen	5	15	Clear
4.	Odour	--	Agreeable		Agreeable
5.	Turbidity	N.T.U	1.0	5.0	1.21
6.	p ^H value	--	6.5 to 8.5	N.R.	7.6
7.	Electrical Conductivity	µmhos/cm	---	---	243.70
8.	Total Dissolved Solid	(mg/l)	500	2000	158.41
CHEMICAL EXAMINATION					
9.	Phenolphthalein Alkalinity	(mg/l)	---	---	NII
10.	Total Alkalinity	(mg/l)	200	600	84.0
11.	Total Hardness	(mg/l)	200	600	123.0
12.	Calcium Hardness	(mg/l)	200	600	82.0
13.	Magnesium Hardness	(mg/l)	200	600	41.0
14.	Calcium as Ca	(mg/l)	75	200	32.8
15.	Magnesium as mg	(mg/l)	30	100	9.84
16.	Ammonia (as NH ₃ -N)	(mg/l)	0.5	N.R.	ND
17.	Nitrite -Nitrogen (N)	(mg/l)	---	---	ND
18.	Nitrate (NO ₃)	(mg/l)	45	N.R.	1.21
19.	Sulphate (SO ₄)	(mg/l)	200	400	34.25
20.	Chloride (Cl)	(mg/l)	250	1000	14.0
21.	Iron (Fe)	(mg/l)	1.0	N.R.	0.03
22.	Fluorides (F)	(mg/l)	1.0	1.5	0.29
23.	Cyanides (CN)	(mg/l)	0.05	N.R.	ND
24.	Residual Chlorine	(mg/l)	0.2	1.0	1.0
BACTERIOLOGICAL EXAMINATION					
25.	Coli form per 100 ml at 37°C	MPN/100 mL	0		0

*N.D. - Not Detectable

Remarks: On the basis of tested parameters, water sample (S1) confirms to drinking water specification I.S.10500:2012 and may be used for drinking purpose.

C.W.A. (W&S)-II

A.C.W.A. (HP- I)

Chemist/Bacteriologist

Asstt. Chemist

